


DIGITAL FLO STEAM/WATER SHELL & TUBE HEAT EXCHANGER SINGLE WALL



PROJECT NAME:

PIPING

CFG

SALES

EXCHANGER SHELL MATL

EXCHANGER TUBE MATL.


DRV SET POINT

TAG:

CONNECTION ITEM DESCRIPTION COLD WATER INLET 1" NPT MIXED WATER OUTLET 1" NPT RECIRC WATER INLET 1" NPT STEAM INLET 2" NPT CONDENSATE OUTLET 3/4" NPT 812 IB ELECTRICAL PANEL/BRAINSCAN 110VAC @ 1.2A 1-1/2" NPT DRV40 N.C. ACTUATED BALL VALVE SAFETY SHUT OFF 1" NPT THERMOMETER (3) 1" NPT CIP CONNECTION (2) SRV(PRESSURE) PIPE TO DRAIN 1" NPT SRV(CONNECTION FOR USER SUPPLIED T&P) 3/4" NPT 3/4" NPT 13 AIR VENT VACUUM BREAKER 1/2" NPT ITEM MATERIAL COPPER TYPE "L"

NOTE(S):

- 1. ALL DIMENSIONS +/- 0.5[13] UNLESS OTHERWISE SHOWN.
- 2. COMPLETE ASSEMBLY LEAD FREE COMPLIANT THE WETTED SURFACE OF THIS PRODUCT CONTACTED BY CONSUMABLE WATER CONTAINS LESS THAN ONE QUARTER OF ONE PERCENT (0.25%) OF LEAD BY WEIGHT.
- 3. PACKAGE INCLUDES ALL REQUIRED INLET CHECK VALVES AND STRAINERS ON DOMESTIC SIDE.
- 4. DRV, SAFETY SHUT OFF AND ELECTRICAL PANEL ARE PREWIRED TO PROVIDE A SINGLE ELECTRICAL LANDING POINT AT THE PANEL.
- 5. ITEM #11 IS 1/4[6.4] PIPE TO DRAIN IF FACTORY PRESS RELIEF VALVE IS USED.



.010 DRAWN

RELEASED

± .005 .010 ± .015 .10

ARMSTRONG INTERNATIONAL Copyright (C) 2010 ARMSTRONG INTERNATIONAL, INC.

CARBON STEEL

85°F

ADMIRALTY BRASS

DF41540BS 1 NPT CPR

CONFIG# (C-118754) DATE

11/18/2013 MATERIAL SHEET 1 OF 1 DWG. D589680